

**CABLURI DE INCALZIRE  
HEATING CABLE**

**Standard de referinta:** SR CEI 60800  
DIN VDE 0253

**Domeniul de utilizare:**

Cablurile sunt utilizate in instalatii fixe pentru confortul termic si protectie impotriva formarii ghetii .Cablul de incalzire are functia de a iradia caldura.

**Temperatura nominala:** +160 °C  
**Temperatura la suprafata:** +70 °C

**Tensiune max de lucru:** 300/500 V  
**Tensiunea de incercare:** 3 kV c.a sau 7.5 kV cc  
**Rezistente de izolatatie:** min 1 M\*km

**Constructie:**

Conductor din sarma rezistiva  
Izolatie: cauciuc  
Ecran : Folie Alu/Pet 21/20 µ  
Fire continuitate: 6x0.2 stanat  
Manta : PVC

**Culoare manta:** neagra (alte culori)

**Marcaj:** Efficient Heating Systems -  
Kanthal Wire – 70oC – 300/500 V  
03.2011 – 00001 m CE

**Distanta intre marcaje:** 1000 mm

**Reference standard:** SR CEI 60800  
DIN VDE 0253

**Applicability:**

The cables are used in fixed installations that provide heating and protection against ice buildup. The cable is designed to emit heat.

**Rated temperature:** +160 °C  
**Surface temperature:** +70 °C

**Max. operational voltage:** 300/500 V  
**Testing voltage:** 3 kV c.a sau 7.5 kV cc  
**Insulation resisitivity:** min. 1 M\*km

**Structure:**

Resistive wire conductor  
Layer: rubber  
Screen: Alu/Pet film 21/20 µ  
Continuity tinned copper wire: 6x0.2 mm  
Sheath: PVC

**Sheath color:** black (other colors)

**Marking:** Efficient Heating Systems -  
Kanthal Wire – 70oC – 300/500 V  
03.2011 – 00001 m CE

**Distance between markings:** 1000 mm

*Simbol cablu: H5YQU2Y 1x0.21mm<sup>2</sup> 70°C*

*Semnificatia:*

*1 - unu conductor*

*0.21 - sectiune sarma rezistiva*

*70°C - temperatura de lucru a cablului*

*H - cablu de incalzire*

*5Y - izolatatie din cauciuc*

*QU - ecran metalic*

*2Y - invelis protector din PVC*

**CABLURI DE INCALZIRE**  
**HEATING CABLE**

<b>Nr cond x Sectiune nominala a cond.</b> <i>Nominal crosssection of conductor mm<sup>2</sup></i>	<b>Nr sarme x diam</b> <i>Conductor construction</i>	<b>Grosime radianta izolatie nom/min</b> <i>Min.insulatio n thickness mm</i>	<b>Grosime radianta manta nom/min</b> <i>Radial thickness of sheath mm</i>	<b>Diametru exterior</b> <i>Outer diameter mm</i>
1x0.21	3x0.3	0.5/0.35	1.1/0.84	4